


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 507 | V-35 | 30

Date 11.03.2025

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the **Stanford International School, Rudhauri Bhawchak, Maharajganj** (Name & Address of the School) on 11.03.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. UPJNMRJ/MARCH/24-25/111 Dated 11.03.2025 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the **Stanford International School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 11.03.2025 to 11.09.2025


 निदेशाधीन अभियन्ता
Executive Engineer (ग्रामीण)
 निर्माण विभाग, नयाँ दिल्ली
Division Office
U.P. Jal Nigar (Rural)
District-Maharajganj

To,

**Stanford International School,
Rudhauri Bhawchak,
Maharajganj.**

Note- The Certificate is to be issued by authorized officer / NABL Lab/Local bodies



District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural), Maharajganj

Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303



TC-12224

Lab ID: T-8716

Analysis Report

Rept. No. UPJNMRJ/MARCH/24-25/111

Date:- 11/03/2025

Page No. 1/2

Customer Name - Stanford International School

Address - Rudhali Bhawchak, Maharajganj

Reference Letter No. -

Basic Details of sample

District- Maharajganj		Block- Maharajganj	
Gram Panchayat/ Nagar	Rudhali Bhawchak, Maharajganj	Village/Nagar	Rudhali Bhawchak, Maharajganj
		Latitude	27.126141
		Longitude	83.505798
Habitation	Rudhali Bhawchak, Maharajganj	Location	School Campus
Water Source	H.P.	Date of S.C.	07.03.2025
Quantity of Sample	1500ml	Sample Collector	By Sampler
Receiving Date	07.03.2025	Analysis Completion Date-	11.03.2025
Sample Receive	Sushil Kumar		
Analysis Start Date	07.03.2025		
Temperature - 25 +-C		Relative Humidity - 50+-15%	

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	1.69	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	TDS	214.00	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
3	pH	8.40	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
4	Total Hardness	202.00	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkanity	270.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	9.68	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	50.59	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Colour	12.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021
9	Magnisum	19.68	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.

Prepared By

Review By

(Radhe Shyam Rawat)
Quality Manager



Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report



District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303

Rept. No. UPJNMRJ/MARCH/24-25/111

Date:- 11/03/2025

Page No. 1/2

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	428.00	mS/cm	NA	NA	IS 3025 (Part 14) : 2017
2	Sulphate	34.21	mg/L	200.00	400.00	IS 3025 (Part 24) : 2022
3	Nitrate	6.27	mg/L	45.00	No relaxation	IS 3025 (Part 34) : 2019
4	Iron	0.25	mg/L	1.00	No relaxation	IS 3025 (Part 53) : 2019
5	Arsenic	0.00	mg/L	0.01	No relaxation	IS 3025 (Part 37) : 2022
6	Floride	0.224	mg/L	1.00	1.50	IS 3025 (Part 60) : 2019
7	E-Coli (Bacteria)	0.00	CFU	Nil	Nil	IS 15181:2016

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless


Prepared By


Review By



Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report