



District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural), Maharajganj

**Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303**



TC-16954

Analysis Report

URL No. TC-16994/26/000000398F	Date 01.04.2026	Page No. 1/2
Customer Name - Principal		
Address - Stainford International School, Rudhauri Bhawchak, District- Maharajganj.		
Reference Letter No. - N/A		

Basic Details of sample

District- Maharajganj

Gram Panchayat/ Nagar	Rudhauri Bhawchak	Village/Nagar	Rudhauri Bhawchak
		Latitude	27.126141
		Longitude	83.505798
Habitation	Rudhauri Bhawchak	Location	Stainford International School, Rudhauri Bhawchak, District- Maharajganj.
Water Source	H.P.	Date of S.C.	30.03.2026
Quantity of Sample	1500ml	Sample Collector	By Samplor
Receiving Date	30.03.2026	Analysis Completion Date-	01.04.2026
Sample Receive	Sampler		
Analysis Start Date	30.03.2026		
Temperature - 25 ±C		Relative Humidity - 50±-15%	

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	1.60	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	TDS	210.00	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
3	pH	7.72	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
4	Total Hardness	184.00	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkanity	232.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	26.00	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	58.75	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Magnisum	10.56	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019
9	Colour	5.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021
10	Sulphate	32.41	mg/L	200.00	400.00	APHA24rd Edition-4500-SO4 Method E (Tubiditometric Method)
11	Nitrate	3.87	mg/L	45.00	No relaxation	APHA24rd Edition-4500-NO3 Method B (UV Screening Method)
12	Iron	0.210	mg/L	1.00	No relaxation	APHA24rd Edition-4500-Fe Method B (Phenanthroline- Method)
13	Arsenic	0.00	mg/L	0.01	No relaxation	APHA24rd Edition-4500-As Method B (Silverdiethylthiocarbamate- Method)
14	Floride	0.220	mg/L	1.00	1.50	APHA24rd Edition-4500-F Method C (Electrode Method)

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

[Signature]
Prepared By

[Signature]
Review By

[Signature]
(Radheshyam Rawat)
Quality Manager
Authorized Signatory
Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report





**District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj**
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303

Date 01.04.2026

Page No. 1/2

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	420.00	mS/cm	NA	NA	IS 3025 (Part 14)
2	E-Coli (Bacteria)	0.00	CFU	Nil	Nil	IS 15181:2016

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

[Signature]
Prepared By

[Signature]
Review By

[Signature]
(Radheyshyam Rawat)
Quality Manager
Authorized Signatory
Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report

Mob.No. 8858396541

Manager

UPIN-RR


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 763 वि० 35/48

Date 01.04.2026

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the **Stanford International School, Rudhauri Bhawchak, Maharajganj.** (Name & Address of the School) on 31.03.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing URL No. TC-16994/26/000000398F Dated 01.04.2026 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the **Stanford International School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 01.04.2026 to 01.10.2026


Executive Engineer
Division Office
U.P. Jal Nigar (Rural)
District-Maharajganj
अधिशायी अभियन्ता
खण्ड कार्यालय उ०प्र० जल निगम (ग्रामीण)
महाराजगंज

To,

**Stanford International School,
Rudhauri Bhawchak,
Maharajganj.**

Note- The Certificate is to be issued by authorized officer / NABL Lab/Local bodies